

# Certificate

## - Indoor Air Comfort - Gold

Product

Manufacturer

The product has undergone a successful testing and evaluation program as specified for Eurofins Indoor Air Comfort Gold certification, version 2.0 (2010). This includes a VOC emission chamber test and an audit of manufacturing site.

### Successful evaluation means:

- No carcinogenic substances were detectable above their limit values, including 4 CMR substances regulated in France.
- Formaldehyde was below the limit value of 10  $\mu\text{g}/\text{m}^3$ .
- Sum of VOC (TVOC) was below the limit values of 1000  $\mu\text{g}/\text{m}^3$  after 3 days and 100  $\mu\text{g}/\text{m}^3$  after 28 days.
- Sum of SVOC after 28 days was below the limit value of 20  $\mu\text{g}/\text{m}^3$ .
- Evaluation of individual VOC: R values were below the limit values of 1 for both German NIK and French LCI lists after 28 days. Sums of VOC without NIK and of VOC without LCI both were below 50  $\mu\text{g}/\text{m}^3$ .
- Quality management system and factory production control program at production site complied with the requirements.
- The product qualifies for the Indoor Air Comfort Gold label.

Validity of certificate:

Certificate No.:

Date:

  
Director Certification Chemical Safety

  
General Manager

**Eurofins Product Testing A/S**  
Tel. +45 70 22 42 76

Sampling, testing and evaluation were performed according to, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1, EN 13419 in the latest versions.

ProductTesting@eurofins.com  
www.product-testing.eurofins.com